

Environmental Remediation Services, Inc.
20 Vernon Street
Norwood, MA 02062
(781) 762-1772
FAX (781) 762-1779

April 3, 2019

Norton Public Schools
PTO Chairperson
c/o Wade Lizotte
64 West Main Street
Norton, MA 02766

RE: Six-Month Surveillance Building Surveys According to the Asbestos Hazard Emergency Response Act (AHERA).

Mr. Lizotte,

Environmental Remediation Services, Inc. was retained to conduct the required six-month surveillance asbestos building assessment of the five Norton Public School buildings. The survey was conducted in accordance with the EPA Asbestos Hazard Emergency Response Act (AHERA) - 40 CFR 763 AHERA 1987. On April 3, 2019 the Six Month asbestos surveys were conducted at the following Norton Public Schools:


Henri A. Yelle Elementary School
L.G. Nourse Elementary School
J.C. Solmonese Elementary School
Norton Middle School
Norton High School

The AHERA Regulation requires that all of the Norton Public Schools be inspected for asbestos, that management plans and response actions are developed, and that periodic surveillance inspections be conducted every six months to ensure the safety of the building occupants. The goal of the inspections is to ensure that all previously identified asbestos materials, and all suspect asbestos containing materials, are intact and do not pose a health threat to building occupants. Under this scope of survey we also collect bulk samples of suspect asbestos containing materials which were not previously sampled but have become physically damaged.

The original Management Plans were developed in 1988 by an AHERA accredited and Massachusetts DLS licensed Asbestos Inspector and Management Planner. At that time a limited amount of bulk sampling was performed that identified some building materials as asbestos containing. The majority of suspect asbestos containing materials were intact and assumed to contain asbestos. ERS, Inc. recommends the periodic surveillance (six months) of all building materials to ensure that asbestos containing materials do not become damaged.

The Management Plans should be available for public inspection at the Schools and at the Manager of Facilities office at 64 West Main Street in Norton, MA. If you have any questions regarding the update of the Management Plan please do not hesitate to give me a call at (781) 762-1772.

Sincerely,
Environmental Remediation Services, Inc.


Daniel J. Slowe
MA Asbestos Inspector AI 60336

Wade Lizotte
LEA

Form 1 - AHERA Asbestos Status Report
Periodic Surveillance & Re-inspection

School Yelle

Year 2019

Periodic Surveillance (every 6 months)

Location	Date	Person Performing	Changes in Condition	Comments
Thayer	4-4-19	DAN STONE	ASBESTOS	→ ALL WICKS EXCEPT TH FOLLOWING REPAIRS NEEDED:
			1) WET WIRE PIPE ENDS IN ROOM 37	
			2) WET WIRE OPEN ENDS (6) IN KITCHEN	
			3) WET WRAP PIPE IN KITCHEN W/ SLIGHT TEARS IN JACKET OF INSULATION (SEE PHOTOS)	

Signed 

Date 4-4-19

Re-inspection (Annually)

Location	Date	Person Performing	Changes in Conditions	Comments

Signed _____

Environmental Remediation Services, Inc.
20 Vernon Street
Norwood, MA 02062
(781) 762-1772
FAX (781) 762-1779

April 3, 2019

Norton Public Schools
PTO Chairperson
c/o Wade Lizotte
64 West Main Street
Norton, MA 02766

RE: Six-Month Surveillance Building Surveys According to the Asbestos Hazard Emergency Response Act (AHERA).

Mr. Lizotte,

Environmental Remediation Services, Inc. was retained to conduct the required six-month surveillance asbestos building assessment of the five Norton Public School buildings. The survey was conducted in accordance with the EPA Asbestos Hazard Emergency Response Act (AHERA) - 40 CFR 763 AHERA 1987. On April 3, 2019 the Six Month asbestos surveys were conducted at the following Norton Public Schools:


Henri A. Yelle Elementary School
L.G. Nourse Elementary School
J.C. Solmonese Elementary School
Norton Middle School
Norton High School

The AHERA Regulation requires that all of the Norton Public Schools be inspected for asbestos, that management plans and response actions are developed, and that periodic surveillance inspections be conducted every six months to ensure the safety of the building occupants. The goal of the inspections is to ensure that all previously identified asbestos materials, and all suspect asbestos containing materials, are intact and do not pose a health threat to building occupants. Under this scope of survey we also collect bulk samples of suspect asbestos containing materials which were not previously sampled but have become physically damaged.

The original Management Plans were developed in 1988 by an AHERA accredited and Massachusetts DLS licensed Asbestos Inspector and Management Planner. At that time a limited amount of bulk sampling was performed that identified some building materials as asbestos containing. The majority of suspect asbestos containing materials were intact and assumed to contain asbestos. ERS, Inc. recommends the periodic surveillance (six months) of all building materials to ensure that asbestos containing materials do not become damaged.

The Management Plans should be available for public inspection at the Schools and at the Manager of Facilities office at 64 West Main Street in Norton, MA. If you have any questions regarding the update of the Management Plan please do not hesitate to give me a call at (781) 762-1772.

Sincerely,
Environmental Remediation Services, Inc.


Daniel J. Slowe
MA Asbestos Inspector AI 60336

Wade Lizotte
LEA

ASBESTOS STATUS REPORT
Form 1 - Periodic Surveillance & Re-inspection

School LG Nazare

Year 2019

Periodic Surveillance (every 6 months)

Location	Date	Person Performing	Changes in Condition	Comments
Mroughart	4-4-19	Dan Slowe	NONE	CONTINUE O&M

Signed [Signature]

Date 4-4-19

Re-inspection (Annually)

Location	Date	Person Performing	Changes in Conditions	Comments

Signed _____

Environmental Remediation Services, Inc.
20 Vernon Street
Norwood, MA 02062
(781) 762-1772
FAX (781) 762-1779

April 3, 2019

Norton Public Schools
PTO Chairperson
c/o Wade Lizotte
64 West Main Street
Norton, MA 02766

RE: Six-Month Surveillance Building Surveys According to the Asbestos Hazard Emergency Response Act (AHERA).

Mr. Lizotte,

Environmental Remediation Services, Inc. was retained to conduct the required six-month surveillance asbestos building assessment of the five Norton Public School buildings. The survey was conducted in accordance with the EPA Asbestos Hazard Emergency Response Act (AHERA) - 40 CFR 763 AHERA 1987. On April 3, 2019 the Six Month asbestos surveys were conducted at the following Norton Public Schools:


Henri A. Yelle Elementary School
L.G. Nourse Elementary School
J.C. Solmonese Elementary School
Norton Middle School
Norton High School

The AHERA Regulation requires that all of the Norton Public Schools be inspected for asbestos, that management plans and response actions are developed, and that periodic surveillance inspections be conducted every six months to ensure the safety of the building occupants. The goal of the inspections is to ensure that all previously identified asbestos materials, and all suspect asbestos containing materials, are intact and do not pose a health threat to building occupants. Under this scope of survey we also collect bulk samples of suspect asbestos containing materials which were not previously sampled but have become physically damaged.

The original Management Plans were developed in 1988 by an AHERA accredited and Massachusetts DLS licensed Asbestos Inspector and Management Planner. At that time a limited amount of bulk sampling was performed that identified some building materials as asbestos containing. The majority of suspect asbestos containing materials were intact and assumed to contain asbestos. ERS, Inc. recommends the periodic surveillance (six months) of all building materials to ensure that asbestos containing materials do not become damaged.

The Management Plans should be available for public inspection at the Schools and at the Manager of Facilities office at 64 West Main Street in Norton, MA. If you have any questions regarding the update of the Management Plan please do not hesitate to give me a call at (781) 762-1772.

Sincerely,
Environmental Remediation Services, Inc.


Daniel J. Slowe
MA Asbestos Inspector AI 60336

Wade Lizotte
LEA

Form 1 - AHERA Asbestos Status Report
Periodic Surveillance & Re-inspection

School J.C. Sabarnese

Year 2019

Periodic Surveillance (every 6 months)

Location	Date	Person Performing	Changes in Condition	Comments
<u>throughout</u>	<u>4-4-19</u>	<u>Dan Slave</u>	<u>None</u>	<u>Continue O & M</u>

Signed _____

Date 4-4-19

Re-inspection (Annually)

Location	Date	Person Performing	Changes in Conditions	Comments
----------	------	-------------------	-----------------------	----------

Signed _____

Environmental Remediation Services, Inc.
20 Vernon Street
Norwood, MA 02062
(781) 762-1772
FAX (781) 762-1779

April 3, 2019

Norton Public Schools
PTO Chairperson
c/o Wade Lizotte
64 West Main Street
Norton, MA 02766

RE: Six-Month Surveillance Building Surveys According to the Asbestos Hazard Emergency Response Act (AHERA).

Mr. Lizotte,

Environmental Remediation Services, Inc. was retained to conduct the required six-month surveillance asbestos building assessment of the five Norton Public School buildings. The survey was conducted in accordance with the EPA Asbestos Hazard Emergency Response Act (AHERA) - 40 CFR 763 AHERA 1987. On April 3, 2019 the Six Month asbestos surveys were conducted at the following Norton Public Schools:


Henri A. Yelle Elementary School
L.G. Nourse Elementary School
J.C. Solmonese Elementary School
Norton Middle School
Norton High School

The AHERA Regulation requires that all of the Norton Public Schools be inspected for asbestos, that management plans and response actions are developed, and that periodic surveillance inspections be conducted every six months to ensure the safety of the building occupants. The goal of the inspections is to ensure that all previously identified asbestos materials, and all suspect asbestos containing materials, are intact and do not pose a health threat to building occupants. Under this scope of survey we also collect bulk samples of suspect asbestos containing materials which were not previously sampled but have become physically damaged.

The original Management Plans were developed in 1988 by an AHERA accredited and Massachusetts DLS licensed Asbestos Inspector and Management Planner. At that time a limited amount of bulk sampling was performed that identified some building materials as asbestos containing. The majority of suspect asbestos containing materials were intact and assumed to contain asbestos. ERS, Inc. recommends the periodic surveillance (six months) of all building materials to ensure that asbestos containing materials do not become damaged.

The Management Plans should be available for public inspection at the Schools and at the Manager of Facilities office at 64 West Main Street in Norton, MA. If you have any questions regarding the update of the Management Plan please do not hesitate to give me a call at (781) 762-1772.

Sincerely,
Environmental Remediation Services, Inc.


Daniel J. Slowe
MA Asbestos Inspector AI 60336

Wade Lizotte
LEA

ASBESTOS SURVEILLANCE STATUS REPORT
Form 1 - Periodic Surveillance & Re-inspection

School Norton Middle School

Year 2019

Periodic Surveillance (every 6 months)

Location	Date	Person Performing	Changes in Condition	Comments
----------	------	-------------------	----------------------	----------

Thru-roof	4-4-19	DAV SLOWE	None	Cont. O & M
-----------	--------	-----------	------	-------------

(New Building)

Signed _____

Date 4-4-19

Re-inspection (Annually)

Location	Date	Person Performing	Changes in Conditions	Comments
----------	------	-------------------	-----------------------	----------

Signed _____

Environmental Remediation Services, Inc.
20 Vernon Street
Norwood, MA 02062
(781) 762-1772
FAX (781) 762-1779

April 3, 2019

Norton Public Schools
PTO Chairperson
c/o Wade Lizotte
64 West Main Street
Norton, MA 02766

RE: Six-Month Surveillance Building Surveys According to the Asbestos Hazard Emergency Response Act (AHERA).

Mr. Lizotte,

Environmental Remediation Services, Inc. was retained to conduct the required six-month surveillance asbestos building assessment of the five Norton Public School buildings. The survey was conducted in accordance with the EPA Asbestos Hazard Emergency Response Act (AHERA) - 40 CFR 763 AHERA 1987. On April 3, 2019 the Six Month asbestos surveys were conducted at the following Norton Public Schools:


Henri A. Yelle Elementary School
L.G. Nourse Elementary School
J.C. Solmonese Elementary School
Norton Middle School
Norton High School

The AHERA Regulation requires that all of the Norton Public Schools be inspected for asbestos, that management plans and response actions are developed, and that periodic surveillance inspections be conducted every six months to ensure the safety of the building occupants. The goal of the inspections is to ensure that all previously identified asbestos materials, and all suspect asbestos containing materials, are intact and do not pose a health threat to building occupants. Under this scope of survey we also collect bulk samples of suspect asbestos containing materials which were not previously sampled but have become physically damaged.

The original Management Plans were developed in 1988 by an AHERA accredited and Massachusetts DLS licensed Asbestos Inspector and Management Planner. At that time a limited amount of bulk sampling was performed that identified some building materials as asbestos containing. The majority of suspect asbestos containing materials were intact and assumed to contain asbestos. ERS, Inc. recommends the periodic surveillance (six months) of all building materials to ensure that asbestos containing materials do not become damaged.

The Management Plans should be available for public inspection at the Schools and at the Manager of Facilities office at 64 West Main Street in Norton, MA. If you have any questions regarding the update of the Management Plan please do not hesitate to give me a call at (781) 762-1772.

Sincerely,
Environmental Remediation Services, Inc.


Daniel J. Slowe
MA Asbestos Inspector AI 60336

Wade Lizotte
LEA

School Newton High School Form 1 - Periodic Surveillance & Re-inspection

HERA Asbestos Status Report

Year 2019

Periodic Surveillance (every 6 months)

<u>Location</u>	<u>Date</u>	<u>Person Performing</u>	<u>Changes in Condition</u>	<u>Comments</u>
<u>Thyngden</u>	<u>4-4-19</u>	<u>Don Sore</u>	<u>None - Asbestos</u>	<u>CONTINUE OK</u>
			<u>(Renovates)</u>	

Signed [Signature]

Date 4-4-19

Re-inspection (Annually)

<u>Location</u>	<u>Date</u>	<u>Person Performing</u>	<u>Changes in Conditions</u>	<u>Comments</u>

Signed _____